



To Planning and Zoning,

Intermountain Gas Company has received your letter of application. In order to best serve this development Intermountain Gas does require that a 5' minimum utility easement along the interior lot lines and a 10' minimum utility easement along all right of ways or private drive. The private drive of the development would also be required to include a utility easement for Intermountain Gas to encroach into with the gas lines.

Thank you for your time and consideration in this matter. If you have any questions or concerns please contact Mishelle Singleton at 377-6863.

Sincerely,

Mishelle Singleton Engineering Tech

rishle Sight

cc: Roger Phillips