Interoffice

MEMORANDUM

DATE: June 16, 2011

TO: Boise Planning & Development

FROM: Ryan Rodgers, Forestry Specialist

Boise Parks & Recreation Department

SUBJ: DRH11-00133 1005 W. Royal Blvd.

The following requirements and recommendations are provided to assist the property owner with selection, placement, maintenance and protection of trees on public and private property.

Required Actions reflect provisions of Boise City Code Title 9, Chapter 16 (Boise Tree Ordinance). Questions relating to these required actions should be directed to this office at (208) 384-4083.

Recommended Actions may be included as a condition of approval, modified or excluded at the request of the Boise Development Services staff.

Existing Trees on public right of way:

None

Required Actions:

- **A)** Class 2 or 3 trees from the Boise Community Forestry Tree Selection guide shall be planted on the public right-of-way.
- **B)** Spacing between trees shall be 30 feet for Class 2 trees and 40 feet for Class 3 trees.

Recommended Actions:

- **A)** In order to provide maximum shade to paved surfaces I would recommend planting class two trees in the proposed parking lot planting sites.
- **B)** To provide ample room for root growth and tree development I would recommend the planting sites in the parking lot be at least 6' x 6' or better yet one continuous planter bed down the center.