

CITY OF BOISE

INTER-DEPARTMENT CORRESPONDENCE

Date: 2/9/2012

To: Planning and Development Services

From: Brian Murphy, Drainage Coordinator
Public Works

Subject: DRH12-00033; ; Drainage/Stormwater Comments

DR01 A drainage plan must be submitted and approved by Public Works prior to issuance of a building permit.

DRHGW High groundwater at this site may preclude use of a subsurface stormwater system.

If you have any further questions contact Brian Murphy, 384-3752.

I:\PWA\Subjects\Review Comments\CUs\CU Drainage comment template.doc