

CITY OF BOISE

INTER-DEPARTMENT CORRESPONDENCE

Date: 5/19/2015

To: Planning and Development Services

From: Rick Christenson, Senior Environmental Specialist
Public Works

Subject: **DRH15-00210**; 7610 W STATE ST; Pretreatment Comments

PT09	Shell and Core Projects - Applicant/Builder shall provide segregated grease line for all tenant spaces with any potential to house food service facilities. More than one outside grease interceptor unit may be required.

For more information, or if you have any questions please contact Rick Christenson, 384-3993 or email at: rchristenson@cityofboise.org.

Conditional Use Design Review Application
SAR095 (Boise)
6.4