

CITY OF BOISE

INTER-DEPARTMENT
CORRESPONDENCE

Date: May 14, 2015

To: Planning and Development Services

From: Mike Sheppard, Civil Engineer
Public Works

Subject: DRH15-00210; 7610 W. State Street; Sewer Comments

Connection to central sewer is required. Sanitary sewers are available onsite. No permanent structures within existing sewer easement.

Prior to granting of final sewer construction plan approval, all requirements by Boise City Planning and Development Services must be met.

If you have any further questions please contact Mike Sheppard at 384-3920.