

Memo

To: Planning and Development Services
From: Megan Durrell, Solid Waste Coordinator, Public Works Department
Date: 5/13/2015
Re: DRH15-00210

Solid Waste staff has reviewed the application for this project and has the following comments:

- The trash enclosure at Building 1 does not meet design criteria.
- The trash enclosure at Building 4 is appears to meet design criteria.
- Trash enclosures lack dimensions to evaluate the appropriateness of the structures.

Please review the trash enclosure design, location, and submittal requirements found here:

<http://curbit.cityofboise.org/commercial/trash-collection/new-construction-design-standards/>

Please contact me with any questions at 388-4712.