

Memo

To: Planning and Development Services
From: Peter McCullough, Public Works Department
Date: 2/17/2016
Re: Solid Waste Comments- CUP16-00006

Solid Waste staff has reviewed the application for this project and has the following comments.

1. The project is located in an area which has alley access; all trash and recycling will be collected from the alleyway.
2. Only 3-yard containers and/or 95-gallon carts can be used for alley collection.
3. If 3-yard containers are utilized they will need to be located in or adjacent to the alleyway.
4. Enclosures are not required for alley service, but if they are used must have a gate opening of at least 10'. If gates are used they must open 120 degrees.
5. Contact Peter McCullough with any questions at 384-3906.