

# CITY OF BOISE

## INTER-DEPARTMENT CORRESPONDENCE

**Date: February 25, 2016**

**To:** Planning and Development Services

**From:** Mike Sheppard, P.E., Civil Engineer II  
Public Works

**Subject:** **SUB16-00006**; 6781 E Warm Springs Ave; Sewer Irrigation Sub Comments

## 1. STANDARD IRRIGATION CONDITIONS

REV 5/1/14

- a. Comply with B.C.C. 11-09-04.11 concerning pressure irrigation requirements prior to signing of the final plat by the Boise City Engineer.
  1. The owner, person, firm or corporation filing the subdivision plat shall provide a pressurized irrigation system. The system must conform to the minimum design standards and specifications of Boise City, or of the entity that will operate and maintain the system, if that entity has published standards; or
  2. The owner, person, firm or corporation filing the subdivision plat shall provide written documentation that a valid waiver of the requirement to provide a pressure irrigation system and that Idaho Code 31-3805(1)(a) regarding transfer of water rights, has been complied with.
- b. Prior to either commencing construction or signing of the final plat by the Boise City Engineer, developer shall:
  1. Submit for approval by the Department of Public Works, construction plans and specifications for the pressurized system, stamped by a registered engineer.
  2. Provide written assurance that provisions have been made for ownership, operation, and maintenance of the system.
  3. Delineate all necessary irrigation easements on the final plat (B.C.C. 11-09-03.6).
- c. Developer shall provide for an independent inspection of the installation of irrigation facilities and written certification by the design or project engineer that the system was installed according to the approved plans. In addition, the Department of Public Works must be present for the system pressure test and participate in a final inspection.
- d. Developer may construct prior to final platting or bond in the amount of 110% of the estimated construction costs based on the approved plans.

- e. **Fees:** Developer and/or owner shall pay the current inspection and plan review fees applicable to the proposed subdivision prior to signing of the final plat by the Boise City Engineer (B.C.C. 11-03-03.3.B.).

## 2. STANDARD SEWER CONDITIONS

REV 5/1/14

### City Subdivision Conditions

- a. Wetline sewers are required (B.C.C. 11-09-04.4., *Required Improvements; Sanitary Sewer*).
1. Plans shall be submitted to and approved by the Boise City Department of Public Works prior to commencing with construction. Developer and/or owner may either construct improvements prior to final platting or execute a performance agreement and provide surety in the amount of 110% of the estimated costs. The developer and/or owner shall coordinate with the Department of Public Works for construction inspection prior to and during construction. Unless otherwise approved by the Public Works Department, all sewer construction shall be completed and accepted within 90 days of plat recordation, or within 30 days of issuance of the first building permit within the subdivision, whichever comes first.
- NOTE:** All bonding shall conform to Boise City Code 1-19, *Surety Bonds*.
2. Developer and/or owner shall pay the current sewer inspection fees for the proposed subdivision prior to signing of the final plat by the Boise City Engineer.
  3. Developer and/or owner shall be responsible for repairs of any failures that occur within one (1) year of the project acceptance by the appropriate sewer entity (Boise City Code 11-09-04.2F, *Subdivision Standards; Required Improvements*).
- b. Developer and/or owner shall delineate all necessary Boise City sanitary sewer easements on the final plat prior to signing of the final plat by the Boise City Engineer (Boise City Code 11-09-03.6A, *Subdivision Design Standards; Easements*).
- c. Unless previously paid, developer and/or owner shall pay a sewer assessment along E Warm Springs Ave and/or as may be approved by the Boise City Public Works Commission prior to signing of the final plat by the Boise City Engineer. Contact the Department of Public Works for specific costs.
- d. Developer and/or owner shall comply with all provisions of the Boise City “Sewer Tap” Ordinances.
1. Developer and/or owner may either construct prior to final platting or post bond/agreement in the amount of 110% of the estimated costs. Please contact the Public Works Department for specifications and inspections during construction.

**NOTE:** All bonding shall conform to B.C.C. 11-09-04.2., *Required Improvements; Filing of Plans and Bonding Surety*, which specifies that the improvements to be made shall be done in a time period not to exceed one year from the date of approval of the final plat.

