

interoffice

MEMORANDUM

November 30, 2016

TO: Design Review Analyst
Boise Planning & Development

FROM: Debbie Cook, Forestry Specialist
Boise Parks & Recreation Department

SUBJECT: CUP16-00088

The following requirements and recommendations are provided to assist the property owner with selection, placement, maintenance and protection of trees on public and private property.

Required Actions reflect provisions of Boise City Code Title 9, Chapter 16 (Boise Tree Ordinance). Questions relating to these required actions should be directed to this office at (208) 608-7700

Required Actions: Trees along the public right of way must be protected during construction with chain link fencing. No material, trailers or vehicles may be stored or parked inside the fence. Irrigation to the trees must be maintained during construction. Trees must be protected from silt or soil buildup that may wash onto the root system during construction. Any injury that may occur to the trees must be reported as soon as possible to Boise Forestry so damage may be assessed and corrected in a timely manner. No treatment may be applied by other than an approved arborist.

Comment: Check into the toxicity of the dwarf English laurel for use at a day care center.

Thank you for the opportunity to comment. If you have any additional questions about trees for this project please don't hesitate to call.

Debbie Cook
Forestry Specialist
Boise Parks & Recreation

208-608-7705

Dcook@cityofboise.org