

SUF7

8248 West Victory Rd.
Boise, ID 83709
Phone: 208. 362. 1300
suezidcustserv@suez-na.com
Fax: 208. 362. 3858
http://www.suez-environnement.com/

EMAIL

TO: Chad Olsen

Envision Homes

EMAIL: chadrbx@gmail.com

DATE: October 28, 2016

CC:

SUBJECT: 1420 W. Front Street

COMMENTS: Available Volume Information

Our records indicate the following water volume at: 1420 W. Front St.:

2,500 gpm

This information represents the volume of water to be used for conditional use permit applications or design review purposes.

Fire Sprinkler Design Information:

Our records indicate the following water pressure and volume at: 1420 W. Front St.:

Pressure at average demand is 65 psi Flow of 2,500 gpm at 20 psi residual pressure

This information represents the water system under maximum-day conditions. The pressures and flows are subject to change, however, depending on system demand and changes in system operations. This document shall be attached to the architectural plan sets, both for "Fire Department reviewed" and "Construction Approved" sets. It is provided for uniformity in fire sprinkler design criteria.

If you have further questions, please feel free to call.

Sincerely, SUEZ