



Dennis Doan
Chief

City Hall West
333 N. Mark Stall Place
Boise, Idaho 83704-0644

Phone
208/570-6500

Fax
208/570-6586

TDD/TTY
800/377-3529

Web
www.cityofboise.org/fire



Mayor
David H. Bieter

City Council
President
Maryanne Jordan

Council Pro Tem
David Eberle

Elaine Clegg
Lauren McLean
TJ Thomson
Ben Quintana

Fire Department

December 28, 2016

Brent Moore
PDS – Current Planning

Re: Conditional Use Permit; CUP16-00088
101 South Capitol BLVD.

Dear Brent,

This is a request for a daycare within an existing office building.

The Boise Fire Department has reviewed and can approve the application subject to compliance with all of the following code requirements and conditions of approval. Any deviation from this plan is subject to Fire Department approval. Please note that unless stated otherwise, this memo represents the requirements of the International Fire Code (IFC) as adopted and amended by Ordinance 6308.

Comments:

1. A building permit will be required for change of use. The building will require life safety upgrades that may include upgrade of fire sprinkler and fire alarm systems. IFC 105.1.11

General Requirement:

Specific building construction requirements of the International Building Code, International Fire Code and Boise City Code will apply. However, these provisions are best addressed by a licensed Architect at time of building permit application.

Regards,

Ron L. Johnson
Division Chief – Assistant Fire Marshal
Boise Fire Department