

# BOISE FIRE DEPARTMENT

## M E M O R A N D U M

TO: Susan Riggs, PDS  
FROM: Mark Senteno  
SUBJECT: CUP09-00017 REVISED  
DATE: April 15, 2009

The Boise Fire Department has reviewed and can approve the application subject to compliance with all following code requirements and conditions of approval. Any deviation from this plan is subject to Fire Department approval. Please note that unless stated otherwise this memo represents requirements of the International Fire Code as adopted and amended by Ordinance 6308.

### Code Requirement:

Fire Department vehicular access shall be provided to within 150' of all portions of the non-sprinklered buildings. Dead end roads are prohibited from exceeding 750 feet. These distances can be increased somewhat for sprinklered buildings but exact distances are on a case-by-case basis. All Fire Department access roads, fire lanes, bridges, and gates are to be a minimum of 20' wide with 13' 6" overhead clearance, shall be capable of supporting 75,000 lbs GVW (25,000 lbs per axle), and shall be paved. Fire Department access roads and fire lanes shall have a minimum outside turning radius of 48' with an inside radius of 28'. Aerial fire apparatus roads shall have a minimum unobstructed width of 26 feet in the immediate vicinity of any building or portion of building more than 30 feet in height, and at least one of the required access routes meeting this condition shall be located within a minimum of 15 feet and a maximum of 30 feet from the building, and shall be positioned parallel to one entire side of the building. Any dead-end road in excess of 150' needs a Fire Department approved turnaround. No grade may exceed 10% (please note that fire apparatus are designed for a maximum 6% grade). Width and turning radius measurements specified by this paragraph can include those surfaces vehicles generally drive upon. Specifically, gutter and rolled curb are generally considered useable, while vertical curb or sidewalks are not.

### Comments:

#### Condition of Approval:

Fire Department vehicular access shall be provided to within 150' of all portions of the non-sprinklered buildings.

Fire Department access roads and fire lanes shall have a minimum outside turning radius of 48' with an inside radius of 28'.

Any dead-end road in excess of 150' needs a Fire Department approved turnaround.

No grade may exceed 10% (please note that fire apparatus are designed for a maximum 6% grade).

Code Requirement:

For streets having a width less than 36 feet back of curb to back of curb parking shall be restricted on (1) one side; for streets having a width less than 29 feet back of curb to back of curb parking shall be restricted on both sides; and for standard ACHD cul-de-sacs parking shall be restricted on both sides. A note on the face of the final plat is required noting the parking restriction prior to signing of the final plat by the Boise City Engineer. In addition, No Parking signs shall be installed in accordance with the requirements of the IFC.

Comments:

Condition of Approval:

Code Requirement:

Fire hydrant location and distribution shall meet requirements of International Fire Code Appendix C.

Comments:

No fire hydrants have been noted. In the absence of information on existing hydrants it appears that one or more new hydrants may/will be needed. However, we reserve the right to modify requirements as more information comes to light. Variables affecting hydrant numbers and location include, but are not limited to, area, construction type, existing hydrants, accuracy of information provided in the application, strategic location for fire fighting forces, and required fire flow. New hydrants must be "non-private" installations.

Condition of Approval:

Have discussed with applicant on 4/8/09 that this project, as submitted, will require a water supply to support the requirement of an approved automatic sprinkler system if change of use becomes a B or A occupancy.

General Requirement:

Fire Department required fire hydrants, access, and street identification shall be installed prior to construction or storage of combustible materials on site. Provisions may be made for temporary access and identification measures.

Specific building construction requirements of the International Building Code, International Fire Code, and Boise City Code will apply. However, these provisions are best addressed by a licensed Architect at building permit application.

Please feel free to have the applicant contact Mark Senteno, 384-3967

cc: File