

# Memo

**To:** Planning and Development Services  
**From:** Peter McCullough, Public Works Department  
**Date:** 12/1/11  
**Re:** Solid Waste Comments- CUP11-0090, 1004 Royal Blvd.

---

City of Boise Solid Waste staff has reviewed the application for this project and has the following comments:

1. Trash enclosures/containers will be required to comply with all Solid Waste Ordinance requirements detailed at:

[http://curbit.cityofboise.org/Trash/Commercial/Commercial\\_Trash\\_Home/page51871.aspx](http://curbit.cityofboise.org/Trash/Commercial/Commercial_Trash_Home/page51871.aspx)

2. 6-yard containers can not be moved by hand (they are not on wheels) so they likely can not be stored inside the building unless 25' of overhead clearance, and all other clearances, are provided.
3. Show details of enclosures/solid waste area (including required access dimensions and containers) in all future plans.

The applicant may contact me with any questions at 384-3906.