



# Fire Department

**Dennis Doan**  
Chief

**City Hall West**  
333 N. Mark Stall Place  
Boise, Idaho 83704-0644

**Phone**  
208/570-6500

**Fax**  
208/570-6586

**TDD/TTY**  
800/377-3529

**Web**  
[www.cityofboise.org/fire](http://www.cityofboise.org/fire)



**Mayor**  
David H. Bieter

**City Council**  
**President**  
Maryanne Jordan

**Council Pro Tem**  
Alan W. Shealy

Elaine Clegg  
David Eberle  
Lauren McLean  
TJ Thomson

January 6, 2012

Joshua Johnson  
PDS – Current Planning

Re: Conditional Use Application – Multifamily mixed use; CUP11-00103  
916 E. Park Blvd.

This is a conditional use application to construct a new 4-story mixed-use apartment building.

The Boise Fire Department has reviewed and can approve the application subject to compliance with all of the following code requirements and conditions of approval. Any deviation from this plan is subject to Fire Department approval. Please note that unless stated otherwise, this memo represents the requirements of the International Fire Code (IFC) as adopted and amended by Ordinance 6308.

Comments:

1. A fire hydrant shall be located so that it is not more than 600-feet from any part of the structure. No hydrants are shown on the drawings.

General Requirement:

Specific building construction requirements of the International Building Code, International Fire Code, International Residential Code and Boise City Code will apply. However, these provisions are best addressed by a licensed Architect at building permit application.

Please feel free to have the applicant contact Romeo Gervais at 570-6567 if they have any questions.

Regards,

Romeo P. Gervais, P.E.  
Deputy Chief – Fire Marshal  
Boise Fire Department