

Dennis DoanChief

City Hall West

333 N. Mark Stall Place Boise, Idaho 83704-0644

Phone

208/570-6500

208/570-6586

TDD/TTY 800/377-3529

Web www.cityofboise.org/fire



Mayor David H. Bieter

City Council
President
Maryanne Jordan

Council Pro Tem Alan W. Shealy

Elaine Clegg David Eberle Lauren McLean TJ Thomson

Fire Department

January 12, 2012

Sarah Schafer PDS – Design Review

Re: Design Review Application - River Edge Apartment; DRH12-00013

1004 W. Royal Blvd.

Dear Sarah,

This is request for a conditional use permit for a five-story, multifamily structure of approximately 351,900 square feet.

The Boise Fire Department has reviewed and can approve the application subject to compliance with all of the following code requirements and conditions of approval. Any deviation from this plan is subject to Fire Department approval. Please note that unless stated otherwise, this memo represents the requirements of the International Fire Code (IFC) as adopted and amended by Ordinance 6308.

Comments:

 It is anticipated that the waterline from Capital Blvd. to Dale St. will need to upgraded to support this project. Required fire flows for the structure maybe up to 4,000 gallons per minute (gpm) based upon final building design. United Water has indicated that 2,000 gpm is currently available and with the waterline upgrades up to 4,000 gpm would be available.

General Requirement:

Specific building construction requirements of the International Building Code, International Fire Code, International Residential Code and Boise City Code will apply. However, these provisions are best addressed by a licensed Architect at building permit application.

Please feel free to have the applicant contact Romeo Gervais at 570-6567 if they have any questions.

Regards,

Romeo P. Gervais, P.E. Deputy Chief – Fire Marshal Boise Fire Department