

Memo

To: Planning and Development Services
From: Peter McCullough, Public Works Department
Date: 1/17/11
Re: Solid Waste Comments- DRH12-00013, River Edge Apartments

City of Boise Solid Waste staff has reviewed the application for this project and has the following comments:

1. The site plan shows two interior "Trash Rooms" however only one of these rooms provides the required vehicular access.
2. The application indicates 8-yard trash containers will be utilized, however only 3-yard containers have wheels and can be moved out of the room for collection.
3. If 3-yard compactors are proposed, specifications for the compactors are required for review prior to approval and compactors must be moved outside the building for collection by building staff.
4. The path from the Trash Room to the parking/loading area must be flat and paved with no curbs or other obstructions.
5. Trash enclosures/containers will be required to comply with all Solid Waste Ordinance requirements detailed at:

http://curbit.cityofboise.org/Trash/Commercial/Commercial_Trash_Home/page51871.aspx

The applicant may contact me with any questions at 384-3906.