



**Dennis Doan**  
Chief

**City Hall West**  
333 N. Mark Stall Place  
Boise, Idaho 83704-0644

**Phone**  
208/570-6500

**Fax**  
208/570-6586

**TDD/TTY**  
800/377-3529

**Web**  
[www.cityofboise.org/fire](http://www.cityofboise.org/fire)



**Mayor**  
David H. Bieter

**City Council**  
**President**  
Maryanne Jordan

**Council Pro Tem**  
David Eberle

Elaine Clegg  
Lauren McLean  
TJ Thomson  
Ben Quintana

## Fire Department

August 22, 2012

Sarah Schafer  
PDS – Current Planning

Re: Design Review Application – Multi-family mixed use; DRH12-00227  
916 E. Park Blvd.

Dear Sarah,

This is a design review application to construct a new 4-story mixed-use apartment building.

The Boise Fire Department has reviewed and can approve the application subject to compliance with all of the following code requirements and conditions of approval. Any deviation from this plan is subject to Fire Department approval. Please note that unless stated otherwise, this memo represents the requirements of the International Fire Code (IFC) as adopted and amended by Ordinance 6308.

Comments:

1. Fire hydrants capable of producing the required fire flows are required to be located within 600-feet of all parts of the facility. No fire hydrants are shown on the drawings but it is anticipated that additional hydrant(s) will be required. (IFC 507.5.1)

General Requirement:

Specific building construction requirements of the International Building Code, International Fire Code and Boise City Code will apply. However, these provisions are best addressed by a licensed Architect at building permit application.

Please feel free to have the applicant contact Romeo Gervais at 570-6567 if they have any questions.

Regards,

Romeo P. Gervais, P.E.  
Deputy Chief – Fire Marshal  
Boise Fire Department