

Memo

To: Planning and Development Services
From: Peter McCullough; Solid Waste Coordinator, Public Works Department
Date: 8/9/12
Re: Solid Waste Comments- DRH12-00227, 916 E. Park

Solid Waste staff has reviewed the application for this project and has the following comments:

1. The trash enclosure should be centered on the drive aisle to provide the 50' of straight line access required.

The link below provides information regarding trash enclosure design, location, and submittal requirements.

<http://curbit.cityofboise.org/commercial/trash-collection/new-construction-design-standards/>

Please contact me with any questions at 384-3906.