

# CITY OF BOISE

## INTER-DEPARTMENT CORRESPONDENCE

**Date: 08/13/12**

**To:** Planning and Development Services

**From:** Terry Alber, Senior Environmental Specialist  
Public Works

**Subject:** DRH12-00227; 916 E Park Blvd; Pretreatment Comments

Shell and Core Projects - Applicant/Builder shall provide segregated grease line for all tenant spaces with any potential to house food service facilities. More than one outside grease interceptor unit may be required. Call Walt Baumgartner 384-3991 for more information.

If you have any questions please contact Walt Baumgartner, 384-3991 or email at [wbaumgarner@cityofboise.org](mailto:wbaumgarner@cityofboise.org).

Or

If you have any questions please contact Terry Alber, 384-3992 or email at [talber@cityofboise.org](mailto:talber@cityofboise.org).