

RYAN P. ARMBRUSTER

251 East Front Street, Suite 300  
Post Office Box 1539  
Boise, Idaho 83701  
Telephone 208 343-5454  
Fax 208 384-5844  
E-mail rpa@elamburke.com

August 14, 2012

**BOISE CITY PLANNING & DEVELOPMENT DEPARTMENT**

150 North Capitol Boulevard  
P. O. Box 500  
Boise, Idaho 83701-0500

RE: CUP12-00046  
Boise State University  
1173 W. University Drive

Ladies and Gentlemen:

The above-referenced Conditional Use Application to demolish and reconstruct a new alumni office/events center located at the above-referenced location has been received in this office. This law firm represents the interests of Ada County Drainage District No. 3 (the "District"). The project site lies within the District's boundaries.

Prior to the issuance of a permit, a drainage plan must be submitted and approved by the District, as well as the Boise City Public Works Department, on the project generally located at 1173 W. University Drive.

The District is responsible for ensuring that its system complies with conditions of a National Pollution Discharge Elimination System ("NPDES") permit issued by the Environmental Protection Agency to the District and other co-permittees, with regard to the quality of storm water runoff.

Approval of any proposed development is based upon the following conditions. Any proposed development must meet the storm water requirements of the Ada County Highway District ("ACHD") (if proposal is for a residential subdivision), or Boise City (if the proposal is for commercial, industrial, multi-family housing, or residential with private streets). This includes any and all requirements pertaining to on-site water detention, water quality treatment, and operation and maintenance. The project may also require a permit from the United States

Army Corps of Engineers under their Section 404 permit program. If the work requires a permit from the Corps, the applicant will need to obtain their approval before starting work.

These requirements are outlined in the ACHD Policy Manual and the Boise City Storm Water Management and Discharge Control Ordinance, the Boise City Storm Water Design Standards Manual, and the Boise City Operation and Maintenance Guidance document.

The objectives of these requirements are to adequately control the quantity and quality of storm water runoff into the District's system and public waters. Compliance with these requirements will also address discharge limitations of "no net increase" in sediment and bacteria, required by the Lower Boise River Total Maximum Daily Load and the Idaho Department of Environmental Quality's "no net increase" policy.

Additionally, the District must be notified of any conditions that result in a significant change to the quantity or quality of the storm water runoff from this site.

If you have any questions or comment concerning the above, please feel free to contact me. Thank you for your assistance.

Very truly yours,

ELAM & BURKE  
*A Professional Association*



Ryan P. Armbruster

RPA/ksk

c: Steve Simmons, LCA Architects  
Jennifer Wheeler, BSU Alumni Association  
District Commissioners  
Steve Sweet  
Dean Callen