

Memo

To: Planning and Development Services
From: Peter McCullough, Public Works Department
Date: 11/16/12
Re: Solid Waste Comments- DRH12-00319, 300 S Capitol Blvd.

City of Boise Solid Waste staff has reviewed the application for this project and has the following comments:

1. Please review the requirements for solid waste enclosures below and submit plans which show enclosure details/dimensions.
2. Enclosures must provide 50' of straight line access for collection vehicles and be sized appropriately.

<http://curbit.cityofboise.org/commercial/trash-collection/new-construction-design-standards/>

The applicant may contact me with any questions at 384-3906.