

CITY OF BOISE

INTER-DEPARTMENT CORRESPONDENCE

Date: 4/10/2015

To: Planning and Development Services

From: Terry Alber, Pretreatment Coordinator
Public Works

Subject: **DRH15-00151**; 7610 W STATE ST; Pretreatment Comments

	All food service operations require “suitable and adequate” grease abatement equipment and must follow established Fat/Oil & Grease Best Management Practices.
	Shell and Core Projects - Applicant/Builder shall provide segregated grease line for all tenant spaces with any potential to house food service facilities. More than one outside grease interceptor unit may be required.

For more information, or if you have any questions please contact Terry Alber, 384-3992 or email at talber@cityofboise.org.

Conditional Use Design Review Application
SAR095 (Boise)
6.4