

CITY OF BOISE

INTER-DEPARTMENT CORRESPONDENCE

Date: 29 September 2016

To: Planning and Development Services

From: Tom Marshall, Street Light Technician
Public Works

Subject: PUD16-00027; 2350 W Kootenai St; Street Light Comments

Street lights are required. Plans for this private street light system must be submitted, reviewed, and approved by Public Works prior to issuance of a building permit. A Homeowners' Association shall be created to be responsible for the ongoing operation and maintenance of the system.

New Street Light installations shall conform to the 2015 version of the Boise Standard Revisions, Idaho Standards for Public Works Construction (ISPMC) using approved LED fixtures listed in Attachment A to the Boise Standard Revisions.

Developer shall not connect, or allow any subcontractor to connect any irrigation timers, decorative lighting, entrance lighting, outlets or other electrical devices to any street lighting circuits. Any and all irrigation timers, decorative lighting, entrance lighting, outlets or other electrical devices shall be connected directly to Idaho Power at an Idaho Power approved location.

If you have any further questions contact Tom Marshall at 388-4719 or tmarshall@cityofboise.org.