

# *West Boise Sewer District*

7608 W. USTICK ROAD / BOISE, IDAHO 83704-5843

PHONE (208) 375-8521 / FAX (208) 327-0894

October 14, 2016

City of Boise  
Planning & Development Services  
P.O. Box 500  
Boise, ID 83701-0500

RE: CUP16-00075  
7901 W Fairview Avenue

ROY R. KAY  
CHAIRMAN

GERALD W. BRESINA  
TREASURER

DAN E. HEALY  
DIRECTOR

J. KENT SULLIVAN  
DIRECTOR

GRAHAM PATERSON  
DIRECTOR

MARY E. BUERSMEYER  
OFFICE MANAGER  
SECRETARY

DAVID C. FILKINS  
MAINTENANCE SUPERVISOR

The above-mentioned property is within the West Boise Sewer District boundaries. Our records indicate that the house currently located on the property is connected to the District's sanitary sewer line. This project can be served provided all regulations and specifications have met the District's approval and all fees having been paid.

In addition, it is the current policy of the District that any establishment which engages in food preparation is required to install and maintain an outside grease interceptor or grease traps as the District may require to prevent the discharge of fats, oils and/or grease into the District's sanitary sewage system.

Detailed plans need to be submitted to West Boise Sewer District showing all plumbing additions proposed as well as site improvements.

If you have any questions contact the West Boise Sewer District Office.

Cordially,



Mary Buersmeyer  
Office Manager  
West Boise Sewer District

cc: ALC Architecture / Jeff Likes  
CH2M Hill / Betsy Roberts